

DUTIES OF FACILITY FIRE INSPECTOR

The facility fire inspector will be responsible for the following:

- (A) Evacuation plans are posted
- (B) Written evacuation plans are in the post orders
- (C) Inmates have been made familiar with evacuation plans
- (D) Communication systems from living area to Control Room are working
- (E) Date of last fire drill is up to date
- (F) Supervisor's log book is up to date
- (G) Proper number of exits to outside
- (H) Locks are in proper working condition
- (I) Keys are in proper working condition
- (J) Keys are coded to locks
- (K) Exit doors are not obstructed
- (L) Stairwell is in safe condition
- (M) Doors work properly
- (N) Emergency keys are kept in central location
- (O) Smoke detectors are working properly
- (P) Fire alarms work properly
- (Q) Other alarms work properly
- (R) Emergency lighting works properly
- (S) Proper number of fire extinguishers available
- (T) Fire extinguishers are properly numbered
- (U) Fire extinguishers are properly located
- (V) Fire extinguishers are in functional condition
- (W) Date of last test of fire extinguishers
- (X) Hose line condition (if applicable)
- (Y) Date of last hose line test (if applicable)
- (Z) Wall sockets are safe
- (AA) Electric fixtures are safe
- (BB) Wiring is safe
- (CC) Exit lights are working properly
- (DD) Storage areas are safe and uncluttered
- (EE) Bedding is of approved type
- (FF) There is no accumulation of combustibles
- (GG) Trash receptacles are of approved type and in safe condition